



AQUA PRO-TECH LABORATORIES
 Certified Environmental Testing

Client: Children's Day Preschool
 104 Jefferson St
 Passaic, NJ 07055

APL Order ID Number: 2101257
 Collected: 10/31/2022 6:40
 Received: 10/31/2022

Contact:
 Client Project: Childrens Day Preschool

Contact: 11/07/2022 15:01
 Customer Service Rep: Tony Tudra

Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
2101257-01	Drinking Water	Gym Bathroom						
Total Metals								
Copper	EPA 200.8	11/3/22 17:38	11/3/22 17:38	0.0928			0.00200	mg/L
Lead	EPA 200.8	11/3/22 17:38	11/3/22 17:38	< 0.00200	U		0.00200	mg/L
2101257-02	Drinking Water	Room 3 Sink						
Total Metals								
Copper	EPA 200.8	11/3/22 17:41	11/3/22 17:41	0.0685			0.00200	mg/L
Lead	EPA 200.8	11/3/22 17:41	11/3/22 17:41	< 0.00200	U		0.00200	mg/L
2101257-03	Drinking Water	Room 2 Sink						
Total Metals								
Copper	EPA 200.8	11/3/22 17:43	11/3/22 17:43	0.0849			0.00200	mg/L
Lead	EPA 200.8	11/3/22 17:43	11/3/22 17:43	< 0.00200	U		0.00200	mg/L
2101257-04	Drinking Water	Room 1 Sink						
Total Metals								
Copper	EPA 200.8	11/3/22 17:51	11/3/22 17:51	0.109			0.00200	mg/L
Lead	EPA 200.8	11/3/22 17:51	11/3/22 17:51	< 0.00200	U		0.00200	mg/L
2101257-05	Drinking Water	Room 8 Sink						
Total Metals								
Copper	EPA 200.8	11/3/22 17:53	11/3/22 17:53	0.100			0.00200	mg/L
Lead	EPA 200.8	11/3/22 17:53	11/3/22 17:53	< 0.00200	U		0.00200	mg/L

Brian Wood
 Laboratory Director

Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
2101257-06 Drinking Water Room 7 Sink								
Total Metals								
Copper	EPA 200.8	11/3/22 17:56	11/3/22 17:56	0.0816			0.00200	mg/L
Lead	EPA 200.8	11/3/22 17:56	11/3/22 17:56	< 0.00200	U		0.00200	mg/L
2101257-07 Drinking Water Room 6 Sink								
Total Metals								
Copper	EPA 200.8	11/3/22 17:58	11/3/22 17:58	0.182			0.00200	mg/L
Lead	EPA 200.8	11/3/22 17:58	11/3/22 17:58	< 0.00200	U		0.00200	mg/L
2101257-08 Drinking Water Room 5 Sink								
Total Metals								
Copper	EPA 200.8	11/3/22 18:01	11/3/22 18:01	0.0912			0.00200	mg/L
Lead	EPA 200.8	11/3/22 18:01	11/3/22 18:01	< 0.00200	U		0.00200	mg/L
2101257-09 Drinking Water Room 4 Sink								
Total Metals								
Copper	EPA 200.8	11/3/22 18:03	11/3/22 18:03	0.115			0.00200	mg/L
Lead	EPA 200.8	11/3/22 18:03	11/3/22 18:03	< 0.00200	U		0.00200	mg/L
2101257-10 Drinking Water Nurse Sink								
Total Metals								
Copper	EPA 200.8	11/3/22 18:06	11/3/22 18:06	0.118			0.00200	mg/L
Lead	EPA 200.8	11/3/22 18:06	11/3/22 18:06	< 0.00200	U		0.00200	mg/L
2101257-11 Drinking Water Kitchen Sink								
Total Metals								
Copper	EPA 200.8	11/3/22 18:08	11/3/22 18:08	0.0981			0.00200	mg/L
Lead	EPA 200.8	11/3/22 18:08	11/3/22 18:08	< 0.00200	U		0.00200	mg/L
2101257-12 Drinking Water Outside Bathroom								
Total Metals								
Copper	EPA 200.8	11/3/22 18:11	11/3/22 18:11	0.115			0.00200	mg/L
Lead	EPA 200.8	11/3/22 18:11	11/3/22 18:11	< 0.00200	U		0.00200	mg/L
2101257-13 Drinking Water First Floor Bathroom								
Total Metals								
Copper	EPA 200.8	11/3/22 18:13	11/3/22 18:13	0.0943			0.00200	mg/L
Lead	EPA 200.8	11/3/22 18:13	11/3/22 18:13	< 0.00200	U		0.00200	mg/L
2101257-14 Drinking Water Second Floor Bathroom								

Brian Wood
Laboratory Director



Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
--------------------------	--------	----------	----------	--------	------	-----	----	-------

2101257-14 Drinking Water Second Floor Bathroom

Total Metals

Copper	EPA 200.8	11/3/22 18:21	11/3/22 18:21	0.122			0.00200	mg/L
Lead	EPA 200.8	11/3/22 18:21	11/3/22 18:21	< 0.00200	U		0.00200	mg/L

2101257-15 Drinking Water Art Therapy Sink

Total Metals

Copper	EPA 200.8	11/3/22 18:23	11/3/22 18:23	0.100			0.00200	mg/L
Lead	EPA 200.8	11/3/22 18:23	11/3/22 18:23	< 0.00200	U		0.00200	mg/L

FootNotes

RL - Reporting limit
 MDL - Minimum detection limit
 ND, U - Indicates compound analyzed for but not detected
 J - Indicates estimated value

B - Indicates compound found in associated blank
 E - Concentration exceeds highest calibration standard
 D - Indicates result is based on a dilution
 P - Greater than 25% diff. between 2 GC columns
 H - Indicates a Hold Time violation
 D1 - Sample was Decanted (Dissolved)

Brian Wood
 Laboratory Director

